EXPRESS TERMS FOR PROPOSED BUILDING STANDARDS OF THE OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT

REGARDING PROPOSED CHANGES TO 2007 CALIFORNIA PLUMBING CODE CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 5

LEGEND FOR EXPRESS TERMS

- 1. Existing California amendments or code language being modified: All such language appears in *italics*, modified language is <u>underlined</u>.
- 2. New California amendments: All such language appears underlined and in italics.
- 3. Repealed text: All such language appears in strikeout.

EXPRESS TERMS

CHAPTER 2 – DEFINITIONS

- - -

210.0

Handwashing Fixture [For OSHPD 1, 2, 3 & 4] is a special application sink having a water supply spout mounted so the discharge point is at least 5 inches (127 mm) above the fixture rim and equipped with hot and cold supply controls not requiring direct contact of the hands for operation. The fixture can not be equipped with an aerator and wrist or elbow blade handles, but may be equipped with a non-aerating laminar flow device. Sensor operated fixtures may be used, provided they are either battery operated or connected to the essential electrical system.

...

CHAPTER 4 – PLUMBING FIXTURES AND FIXTURE FITTINGS

TABLE 4-2 [For OSHPD 1, 2, 3 & 4] Minimum Plumbing Facilities

Space	Handwashing Fixture	Scrub Sinks	Toliets Toilets	Bathtubs or Showers	Service Sinks ¹	Clinic Sinks
OSHPD 1						
General Acute – Care Hospitals and Acute Psychiatric Hospitals						
Administration Space						
Lobby						
Male	12		1			
Female	1 ²		1			
Airborne infection isolation rooms ⁵	2 ⁵		1 ⁵	1 ⁵		
Cardiac Catherization Catheterization						

Procedure room		14	1		1	
Staff clothing changing areas	1	1	1	1 shower	1	
Central Sterile Supply	115		'	1 SHOWEI		
Cesarean/delivery Service Space	1					
Labor Rooms	1		19	1 ⁹		
Recovery Room	1		'	,		1
Drug distribution station	1					,
Cesarean operating room 10	'	2 <u>10</u>				
Cesarean operating room ¹⁰ Delivery room ¹⁰		2 ¹⁰ 1 ¹⁰				
Staff clothing changing areas		,				
Male	1		1	1		
Female	1		1	1		
Staff lounge toilet	1		1	,		
LDR or LDRP room	1		1	1		
Waiting room	12		126	,		
Clinical Laboratory Service Space ¹¹	1		'			
Dietetic Service Space	1					
Toilets and lockers	'		1			
			'			
Emergency Service						
Standby emergency medical service.						
Lobby – public toilets	1		1			
Treatment room	1.4		4			
Open plan	1:4 cubicles		1 <u>1</u>			
Patient toilet	1		<u> </u>			
Administrative center/nurses' station	1:4 cubicles					
Observation units[RELOCATED BELOW]	1.4 CUDICIOS					
Basic emergency service						
Public waiting			1			
Treatment areas, more than 8			2			
Treatment room	1					
Open plan	1					
Ореп ріап	,					
Observation units	1:4 cubicles		1:8			
Observation arms			cubicles			
			<u> </u>			
Emergency surgery, Cystoscopy, or Special		1			1	
procedure room						
Employee dressing rooms						
Male ²	1 ²	-1	1			
Female	1 ²		<u>1</u>			
Exam and treatment rooms	1					
Housekeeping room					1	
Intensive Care Units ⁷						1
Open plan	1:3 beds					
Patient rooms ²⁸	1					
Staff lounge	1 ²		1			
Newborn Intensive Care Unit (NICU)	1:4 bassinets ¹⁷					1
Control station	1		1			
Staff lounge	1 ²		1			
Laboratories	115		1		1	
Laundry	· ·		1		•	
Soiled linen	1		1			
Medicine preparation rooms or station	1		1			
Morgue and Autopsy	1		1		1	
Nourishment station or center	1 ²		1		•	
Nuclear medicine	,		1			
Procedure room	1		1			
	ı.			1		

Mold room	1					
Radiotherapy	,					
Reception/waiting area	1 ²		1			
Nursing service space	1		'			
Administrative center or nurse station	1		<u>1</u>			
Examination or treatment room	1		<u> </u>			
	1					
Patient room Patient toilet and bath facilities ¹³	12		1:4 beds	1:12 ¹⁶		
Administrative contexturring atotion	I			1.12		
Administrative center/nursing station Multi-purpose rooms ²⁷			1 ²			
			1			
Central bathing facility Staff toilet room	1 ²		1			
	1		,			
Medicine preparation room	1					
Nourishment area Nurses' stations ⁹ or administration center	1					
	1					
Nurseries	4.0 /					
Well Newborn	1:6 bassinets					
Exam/Workrooms	1		1			
Outpatient service space			1			
Outpatient surgery		1	1			
Endoscopy examination room	1		1			
Pediatric and Adolescent Unit] .			
Patient room	1		1			
Play areas toilet room	1		1			
Central bathing toilet room	1		1			
Pharmacy	1 ²⁵		1			
Postanesthesia care units (PACU)	1			-		1
Protective environment room⁵	2 ⁵		1 ⁵	15		
Psychiatric Nursing Unit						
Patient room	1 1 ²			40		
Patient toilet and bath facilities ¹³			1	1:12 ¹⁶		
Radiological/Imaging Services Space	1		00			
Computerized tomography (CT)	12		1 ²⁹			
Ultrasound	12	,	1 ²⁹			
Angiography	12	1 ⁴	1 ²⁹			
Flouroscopy ⁸	12		1			
Patient toilet	1 ² 1 ² 1 ² 1 ² 1 ²		1_			
Staff toilets	1 ²		1 ¹⁸			
Rehabilitation Therapy Space						
Patient Waiting area	_		1			
Male	1 ² 1 ²		1			
Female	1 ²		1			
Training toilet			1			
Physical therapy service space	1		1			
Occupational therapy service space	1		1			
Speech pathology	1		<u> </u>			
Renal Dialysis Service Space	1:4 stations					1
Dialysis Bloodborne Infection Isolation Room	1		1			
Nurses station	1		1			
Medication dispensing	1		1			
Home training room	1		1			
Repair room	1		1		1	
Patient toilet	1		1			
Staff lounge	1		1	1 shower		
Waiting room toilet	1		1			
Surgical Service Space		2 ³				
Staff clothing change areas	_		1			
Male	1 ²		1	1 shower		

- ·	1 42	1	1 4	1 4 1		
Female	1		1	1 shower		
Clean-up rooms	1					
Substerile area	1 ⁸					
Anesthesia workroom	1					
Soiled workroom or soiled holding	1					1
Utility Room						
Clean ⁹ 27	1					1 ¹² 14
Soiled ⁹⁻²⁷	1					11214
OSHPD 2						
Skilled Nursing or Intermediate Care Facilities						
Nurses' Station	1					
Utility room	1					
Clean	1 1 ²¹					
Soiled	1 ²² 1:8 ²					1 ¹⁴
Patient beds	1:8 ²		1:6	1:20		
Administration space – public toilets			1			
Employee lockers	1 ² 1 ²		1			
Male	1 ²		1			
Female			1			
Outpatient waiting room	1					
Laundry	-					
Dietetic service space	1					
Kitchen	1					
Food serving area	1					
Employee washroom	1					
Airborne infection isolation room ⁵	15		15	1 5		
Protective environment room ⁵	1 1 ⁵ 1 ⁵		1 ⁵ 1 ⁵	1 ⁵ 1 ⁵		
Medicine rooms ¹⁹	1 ¹⁵		,	'		
Optional services	1					
Physical therapy	'1					
	1					
Occupational therapy	1					
Speech pathology/Audiology	<i>'</i>				_	
Housekeeping room					1	
OSHPD 3						
Licensed Clinics and any freestanding						
building under a hospital license where						
outpatient clinical services are provided	4					
Examination and treatment rooms	1				_	
Primary care clinic	1 ¹⁵				1	
Utility room	1.5				_	
Birthing Clinic	1				1	
Clean-up room	1					
Toilet room	12	- 3	1		_	
Surgery Clinic		2 ³			1	
Clean-up room	1					
Outpatient changing	1 ²		1			
Postanesthesia recovery	1					
Chronic Dialysis					1	
Nurse station	1:8 patients		25			
Patient	1		1 ²³			
Staff lockers	1 ²		1			
Airborne Bloodborne infection isolation room	1					
Utility room	1				1	
Home training	1					
Rehabilitation Člinics						
Physical therapy space	1					
Occupational therapy	1					
Speech pathology/Audiology	1					

Housekeeping room				1	
OSHPD 4					
Correction Treatment Centers ¹					
Nurse station	1				
Utility Room					
Clean	1 ²¹ 1 ²² 1:8 ²				
Soiled	1 ²²				
Patients	1:8 ²	1:6	1:12		
Employee dressing rooms	_				
Male	1 ²	1			
Female	1 ²	1			
Outpatient services		1			
Airborne infection isolation room ⁶	16	1 ⁶	1 ⁶		
Protective environment room ⁶	16	1 ⁶	1 ⁶		
Medicine rooms ¹⁹	1 ¹⁵				
Treatment and Exam Rooms	1				
Toilets					
Patient ¹³	1:8 ²	1:6	1:12		
Staff	12	1			
Employee dressing rooms and lockers					
Male	1 ²	1			
Female	12	1			
Outpatient services					
Waiting area	1 ²	1			
Housekeeping room				1	
Soiled utility room	1				
Pharmacy	1				

- 1 Each department or nursing unit shall be served by a housekeeping room equipped with a service sink. Departments may share service closets provided the departmental services are compatible. The fixtures listed cannot be shared.
- 2 Conventional spouts and controls on hot-and cold-water supplies are acceptable. Aerators are not permitted. Non-aerating laminar flow devices are permitted. Nourishment stations shall have a handwashing fixture in or immediately accessible from the nourishment area.
- 3 A minimum of two scrub sinks shall be provided in a surgical unit containing one operating room. Four scrub sinks shall be provided in surgical units containing two operating rooms. One additional scrub sink shall be provided per each additional operating room.
- 4 The scrub sink is in addition to the required number for surgeries.
- 5 The following fixtures shall be provided in airborne infection or protective environment rooms of hospitals only:
- a. Within an adjoining toilet room, a handwashing fixture, a shower containing a seat or a space for a shower chair, and water closet equipped with bedpan flushing attachment with a vacuum breaker.
- b. A handwashing fixture within a separate anteroom.
- Exception: 1. Chemical dependency recovery hospitals. 2. In emergency department, separate toilet/shower not required. 6 The following fixtures shall be provided in isolation rooms of correctional treatment centers only:
- a. Within an adjoining toilet area, a handwashing fixture, a shower containing a seat or a space for a shower chair, and water closet equipped with bedpan flushing attachment with a vacuum breaker.
- b. A handwashing fixture within a separate anteroom.
- 7 Includes burn center spaces and acute respiratory-care service spaces, coronary-care service spaces.
- 8 A tollet room with handwashing fixture shall adjoin each fluoroscopy room.

 9 One tollet with lavatory and one shower may serve more than one two labor rooms.
- 10 One additional scrub sink per cesarean or delivery operating room.
- 11 Provide emergency eye-wash and shower.
 12 Handwashing fixtures shall be located in convenient locations throughout the space.
- 13 Fixtures serving individual patient rooms shall not be considered as meeting the required ratios for bedrooms not served by individual adjoining toilet or bathrooms.
- 14 The clinic sink may be deleted if all bedrooms in the nursing unit are provided with adjoining toilets with bedpan flushing devices.

 15 Conventional controls on hot-and cold-water supplies are acceptable. The water discharge points shall be <u>5 inches</u> (127 millimeters) (5 inches) above the fixture rims. and equipped without a Aerators are not permitted. Non-aerating laminar flow devices are permitted.
- 16 A minimum of one bathtub is required on each floor of an acute care or acute psychiatric hospital providing skilled nursing or intermediate care services.
- 17 In a multiple-bed room, every bed position shall be within 20 feet (6 meters) of a hands-free handwashing fixture. Where an individual room concept is used, a handwashing fixture shall be provided within each infant care room.
- 18 When three or more procedure rooms are provided.
- 19 If a separate medicine room is provided, the room shall be equipped with a sink in addition to the nurses' station handwashing fixture. Hot-water supplies are optional.
- 20 Chemical dependency recovery hospitals are only required to provide handwashing fixtures for exam rooms and kitchens. All other fixtures may be equipped per **NOTE** Footnote 2.
- 21 Handwashing fixtures may be deleted if room is storage and holding only.
- 22 Handwashing fixtures may be deleted if room is temporary holding of soiled materials.
- 23 Toilet shall be equipped with a bedpan flushing attachment.
- 24 Optional services approved by the licensing agency shall comply with the applicable space requirements of OSHPD 1 and 2.

- 25 Shall be provided in each separate room where open medication is handled.
- 26 Conveniently accessible throughout the unit.
- 27 Includes rooms or areas within coronary and intensive-care units and postanesthesia recovery rooms.
- 28 Modular toilet/sink combination units located within a privacy curtain may be used within each patient space or private room.
- 29 Toilet room facilities located adjacent to or in the immediate vicinity are adequate.

CHAPTER 6 – WATER SUPPLY AND DISTRIBUTION

604.0 Materials.

604.1 All pipe, tube, and fittings carrying water used in potable water systems intended to supply drinking water shall meet the requirements of NSF 61 as found in Table 14-1. All materials used in the water supply system, except valves and similar devices, shall be of a like material, except where otherwise approved by the Authority Having Jurisdiction

Materials for building water piping and building supply piping shall be in accordance with Table 6-4 and the standards in Table 14-1.

Exceptions:

- (1) **[For OSHPD 1, 2, 3 & 4]** Use of CPVC is not permitted for applications under authority of the Office of Statewide Health Planning and Development.
- (2) **[For OSHPD 1, 2, 3 & 4]** Use of PEX piping is not permitted for applications under the authority of the Office of Statewide Health Planning and Development. <u>Installation and use of PEX tubing shall be in accordance with manufacturer's installation standards. PEX piping shall not be used for any application that would result in noncompliance with any provisions of the California Building Standards Code.</u>

...

- **604.11 PEX.** *[Not adopted by OSHPD 1, 2, 3 & 4]* Cross-linked polyethylene (PEX) tubing shall be marked with the appropriate standard designation(s) listed in Table 14-1 for which the tubing has been approved. PEX tubing shall be installed in compliance with the provisions of this section. [*For OSHPD 1, 2, 3, & 4] Installation and use of PEX tubing shall be in accordance with manufacturer's standards. PEX piping shall not be used for any application that would result in noncompliance with any provisions of the California Building Standards Code.*
- **604.11.1 PEX Fittings.** *[Not adopted by OSHPD 1, 2, 3 & 4]* Metal insert fittings, metal compression fittings, and cold expansion fittings used with PEX tubing shall be manufactured to and marked in accordance with the standards for the fittings in Table 14-1. [*For OSHPD 1, 2, 3, & 4*] *Installation and use of PEX tubing shall be in accordance with manufacturer's standards. PEX piping shall not be used for any application that would result in noncompliance with any provisions of the California Building Standards Code.*
- **604.11.2 Water Heater Connections.** *[Not adopted by OSHPD 1, 2, 3 & 4]* PEX tubing shall not be installed within the first eighteen (18) inches (457 mm) of piping connected to a water heater.

..

605.0 Valves.

...

605.8 [For OSHPD 1, 2, 3 & 4] Each riser or branch shall be provided with an accessible sectionalizing valve in hot and cold-water systems to permit servicing or replacement of piping or equipment. Stop valves shall be provided at each fixture.

MATRIX TABLE CHAPTER 6 – WATER SUPPLY AND DISTRIBUTION

Proposed Adoption		OSI	НPD	ı	Comments
	1	2	3	4	
Adopt entire chapter without amendments					
Adopt entire chapter with amendments listed below	Х	Х	X	Х	
Adopt only sections listed below					
604.1 Except #1 CA	Χ	Χ	Χ	Х	
604.1 Except #2 CA	X	X	X	X	
604.1 Except #3 CA	Х	Х	Χ	Х	
604.10	Х	Х	Χ	Х	
604.11 CA	‡	‡	#	‡	
604.11.1 CA	‡	‡	‡	‡	
604.11.2 CA	‡	‡	#	‡	
604.13	†	†	†	†	
604.13.1 CA	†	†	†	†	
604.13.2 CA	†	†	†	†	
605.8 CA	Χ	Χ	<u>X</u>	Х	
606.2.4.1 CA	Х	Χ	Χ	Х	
609.9 CA	Χ	Χ	Χ	Χ	
609.11 CA	Χ	Х		Х	
612.0 CA	Χ	Χ	Χ	Х	
613.0 CA	Χ	Χ	Χ	Χ	
614.0 CA	Χ	Χ	Χ	Х	
614.1 CA	Χ	Χ	Χ	Χ	
614.2 CA	Χ	Χ	Χ	Χ	
614.3 CA	Χ	Χ	Χ	Χ	
614.4 CA	Χ				

Notation

Authority: Health & Safety Code Sections 1226, 1275, and 129850; Government Code Section 11152.5 References: Health & Safety Code Sections 1226, 1275, 129790, and 129850